



---

## ARCHITECTURAL TECHNICAL BULLETIN

---

**PRODUCT:**

IWP Series – Insulated Metal Wall Panel  
IRP Series – Insulated Metal Roof Panel  
Component: Polyisocyanurate (PIR) insulating foam core  
System: Rubitherm WR 40618 / Rubinate 1850  
Blowing Agent: Non-ozone depleting Pentane (C<sub>5</sub>H<sub>10</sub>)

**TEST PROTOCOL:**

ASTM E 84-11b Test for Surface Burning Characteristics of Building Materials

**TEST LOCATION:**

INTERTEK, 16015 Shady Falls Road, Elmendorf, TX 78112

**REPORT NUMBER:**

100595219SAT-012A

**RESULTS:**

Flame Spread Index	20
Smoke Developed Index	300

---

**ATB-0002**

**MARCH 21, 2012**

*SUBJECT TO CHANGE WITHOUT NOTICE – Please visit our website for the most current information*